



This system was tested at CNC Testing Laboratory in Seoul, South Korea. With nearly 70 people in attendance, the following tests were performed:

Static Air – Pre-Load (ASTM E 330)	<b>PASSED</b>	Static Air Infiltration (ASTM E 283)	<b>PASSED</b>
Static Water Penetration (ASTM E 331)	<b>PASSED</b>	Dynamic Water Penetration (AAMA 501.1)	<b>PASSED</b>
Static Air – Design Load (ASTM E 330)	<b>PASSED</b>	Repeat Static Air Infiltration (ASTM E 283)	<b>PASSED</b>
Repeat Static Water Penetration (ASTM E 331)	<b>PASSED</b>	Lateral Movement (AAMA 501.4)	<b>PASSED</b>
Thermal Cycling (AAMA 501.5)	<b>PASSED</b>	Condensation (by spec)	<b>PASSED</b>
Repeat Static Air Infiltration (ASTM E 283)	<b>PASSED</b>	Repeat Static Water Penetration (ASTM E 331)	<b>PASSED</b>
Repeat Static Air Infiltration (ASTM E 283)	<b>PASSED</b>		



**EN-WALL System Mockup  
Installed in EN-WALL's in-house test  
chamber in Las Vegas, NV, USA**

**EN-WALL Songdo City Mockup  
Installed at CNC Testing Laboratory  
Seoul, South Korea**

